

TRI-COUNTY RURAL ELECTRIC COOPERATIVE, INC.

POLICY BULLETIN NO 3-7

SUBJECT: TESTING METERS

I. POLICY:

To provide the member with the most accurate billing possible, the Cooperative will test the member's meter on a regularly scheduled basis in addition to testing the meter at the member's request.

II. PROCEDURE:

- A. All meters will be tested on a regularly scheduled basis by trained co-op personnel. The tolerance will be 2 percent fast or slow.
1. Single-phase meters will be tested within a ten (10) year cycle.
 2. Special single-phase and three-phase meters will be tested within a four (4) year cycle.
 3. Billings will be corrected to a determinable date or reading based on past history of the account when a meter has stopped, when it has incorrectly metered use or when an incorrect reading has been used. If undeterminable, then adjustments will be made for a four (4) month period based on four (4) months use.
- B. A member may request to have a meter tested by paying a test fee (see Schedule of Fees). This fee will be refunded if results are outside of tolerances.
1. A copy of test results will be mailed to the member.

III. RESPONSIBILITY:

President & CEO or Designee

Approved: 6/19/79.

Revised: 2/16/82, 3/20/84, 2/13/85, 11/18/97, 11/17/98, 10/23/07.